

GSA Specification

(Facilities Standards for the Public Buildings Service)

Section Five, Sub-Section 5.9, Page 143,
HVAC Systems and Components
Revised March 2003 – PBS-P100

UVC Emitters/Lamps: Ultraviolet light (C band) emitters/lamps shall be incorporated downstream of all cooling coils and above all drain pans to control airborne and surface microbial growth and transfer. Applied fixtures/lamps must be specifically manufactured for this purpose. Safety interlocks/features shall be provided to limit hazard to operating staff.